

ASP - BTS EQUIPMENT PLATFORM DESIGN CHECK

For
NT1010-0-0A Support Platform
Pensacola, Florida

Prepared For:

ADVANCED SUPPORT PRODUCTS, INC
Tomball, TX

By:

Ray Ullrich, P.E.

Oct. 08, 2002

NT1010-0-0A BTS Equipment Platform

PROJECT DESCRIPTION: Calculation of loads for a typical BTS equipment platform, to be located in Pensacola, Florida. Loads are calculated as per ASCE7-98 and applied in a finite element model. The platform will be located on a rooftop. Rooftop or any substructure analysis is not in the scope of this analysis.

Applicable codes: ASCE7-98, Conforms to 1999 Standard Building Code, IBC 2000 & Florida Building Code (140 mph, 3 sec. gust)

INPUT DATA

-Structure Data-

(data provided by ASP)

Cabinets

Dimensions-

Maximum wind speed	V := 140 mph	Cabinet height	H _{cab} := 6 ft	
Max. height from ground	H _{rf} := 195 ft	Cabinet width -total	W _{cab} := 8 ft	
Building exposure	= "D"	Cabinet depth	D _{cab} := 3.3 ft	(at support points)

INPUT WIND LOAD PARAMETERS

Exposure "D" -section 6.5.6 - ASCE7-98

V := 140 mph - Basic wind speed (3 sec gust at 33') Fig 6-1 ASCE 7-98

C_f := 1.2 Force coefficient Table 6-11, ASCE 7-98

G := 0.85 Gust response factor for Exposure "D" category 6.5.8. ASCE 7-98

K_z := 1.61 Velocity pressure coefficient, Exposure "D" - table 6-5 ASCE 7-98

K_{zt} := 1 Wind speed over hills & escarpments Edn. 6-1 & Fig 6-2 ASCE 7-98

I := 1.15 Importance factor, Communication facility. Table 6-1 ASCE 7-98

CALCULATION

-Wind pressure-

$q_z := 0.00256 K_z \cdot K_{zt} \cdot V^2 \cdot I \cdot \text{psf}$ $q_z = 92.9 \text{psf}$

-Wind load on the Equipment-

Calculate the effect of wind loading from the cabinet to the platform

Front $F_f := H_{cab} \cdot W_{cab} \cdot q_z \cdot C_f \cdot G$ $F_f = 4.55 \text{kips}$

Linear shear load $S_{clin} := \frac{F_f}{W_{cab} \cdot 2}$ $S_{clin} = 284.28 \text{plf}$

Moment from wind load $M_{cab} := F_f \cdot \frac{H_{cab}}{2}$ $M_{cab} = 13.65 \text{ft_kip}$

Couple from moment at base $C_{base} := \frac{M_{cab}}{D_{cab}}$ $C_{base} = 4.13 \text{kip}$ (up & down)

linear couple $P_c := \frac{C_{base}}{W_{cab}}$ $P_c = 516.87 \text{plf}$

-Weight of cabinets-

Total weight of cabinets: 3100 lbs $WT_{cab} := 3100 \cdot lb$ Weight of platform
Cabinets will be placed along the angle supports. $WT_{pl} := 1311 lb$
 $L_{sup} := 8 \cdot ft$

$$WT_{cabuni} := \frac{WT_{cab}}{2 \cdot L_{sup}} \quad WT_{cabuni} = 193.75 \text{ plf}$$

-Grating weight-

Grating (1"x3/16") $UW_{gr} := 7.6 \cdot psf$

Loading on the runners

$$\text{Spacing } S_{out} := 2.43 \cdot ft$$
$$WT_{gr1} := UW_{gr} \cdot S_{out} \quad WT_{gr1} = 18.47 \text{ plf}$$

-Live Load-

$L_L := 60 \cdot psf$ (unoccupied structure - use same as walkways & elevated platforms)

Loading on the runners

$$\text{Spacing } S_{out} := 2.43 \cdot ft$$
$$WT_{Live} := L_L \cdot S_{out} \quad WT_{Live} = 145.8 \text{ plf}$$

The above calculated loads are input in the finite element model. Refer to FEM printout for results.

From FEM output

Max. deflection $\Delta_{max} := 0.019 \cdot in$

Max member stress ratio $\alpha_{max} := 0.454$

Overtuning stability check

$$\text{Overtuning moment from wind} \quad M_{OT} := F_f \cdot \frac{(H_{cab} + 1 \cdot ft)}{2} \quad M_{OT} = 15.92 \text{ ft_kip}$$

$$\text{Resisting moment from weight} \quad M_{res} := (WT_{cab} + WT_{pl}) \cdot 10 \cdot \frac{ft}{2} \quad M_{res} = 22.05 \text{ ft_kip}$$

$$SF := \frac{M_{res}}{M_{OT}} \quad SF = 1.39 < 1.5 \quad \text{NG. need additional ballast weight.}$$

Additional ballast required

$$WT_{ball} := \left[\frac{M_{OT} \cdot 1.5}{\left(10 \cdot \frac{ft}{2}\right)} \right] - (WT_{cab} + WT_{pl}) \quad WT_{ball} = 364.85 \text{ lb}$$

Provide 400 lbs of additional ballast $WT_{ball} := 400 \cdot lb$

Tiedown check

$$w_{TD} := 2 \cdot \text{in}$$

$$t_{TD} := 0.25 \cdot \text{in}$$

$$F_y := 36 \cdot \text{ksi}$$

Tie down - 2"x.25" plate Length $L_{TD} := 6.3 \cdot \text{ft}$

$$A_{TD} := w_{TD} \cdot t_{TD}$$

Check sliding due to wind

Coefficient of friction $f := .5$ Conservative

$$P_{res} := (WT_{cab} + WT_{pl} + WT_{ball}) \cdot f \quad P_{res} = 2405.5 \text{ lb} < F_f = 4548.43 \text{ lb}$$

Therefore platform weight is not enough to resist sliding loads from wind. Tiedowns needed. Provide tiedowns to resist the sliding forces.

Load to be resisted by tie down

$$P_{TD} := F_f - P_{res} \quad P_{TD} = 2142.93 \text{ lb}$$

Building engineer to design new tie downs to carry the additional sliding forces.

From the results of the calculations, the NT1010-0-0A platform is adequate to support the proposed equipment for a wind speed of 140 mph, 3 second gust loading and the BTS equipment listed above, with the addition of 400 lbs of ballast and new tiedowns. The scope of this calculation is limited to the structural integrity of the steel frame of the ASP platform and does not include the load carrying capacity of the rooftop or any substructure where platform is to be located.